

## DCA125SPK3– 100kva Generator/Engine Fuel Consumption & Comparison Data

ENGINE MAKE & MODEL	CAT/PERKINS 1104L-TAG2 100KVA PRIME	CUMMINS 4BT5.9 G6 100KVA PRIME	JOHN DEERE 4045H 100KVA PRIME	KOMATSU SA6D105E-1-A 100KVA PRIME
Fuel Consumption @ 75% load - L/Hr	18.07	17.8	16.5	15.5
Fuel Consumed running 168Hrs/week - L	3,035.76	2,990	2,772	2,604
Fuel Consumed over 12 months - L	158,510.04	156,141.60	144,738	135,966.0

