


ALL WELDS TO BE 8 mm.(MIN)
 FILLET OR BUTT WELDS
 UNLESS STATED
 OTHERWISE
 ALL WELDS TO BE : AS1554
 INTERSTITIAL LEAKAGE TEST AT 35 KPA

NOTE:
 1: ACTUAL VOLUME: 80,000 L.
 2: TANK MASS : 17 t.

PART	FINISH	TOLERANCES: ALL DIMENSION IN MM	DRAWN	CK	DATE	09-06-2012	TITLE			
			DESIGN/CHECKED		DATE					80,000L Redstar Self Bunded Tank
			APPROVED	CK	DATE	09-06-2012	DRAWING NO HT80PB-48-GA-A01	SHEET 1 OF 1		
			CONFIGURED		DATE					SCALE:
MATERIAL										A3



ALL WELDS TO BE 8 mm.(MIN)
 FILLET OR BUTT WELDS
 UNLESS STATED
 OTHERWISE
 ALL WELDS TO BE : AS1554
 INTERSTITIAL LEAKAGE TEST AT 35 KPA

NOTE:
 1: ACTUAL VOLUME: 80,031 L.
 2. SFL (L.B.S) VOLUME: 77,22L.
 3: TANK MASS: 15,728 KGS.
 4: MA G. W: KGS

PART	FINISH	TOLERANCES: ALL DIMENSION IN MM	DRAWN	DATE	TITLE
			CK	09-06-2012	
MATERIAL	O		DESIGN/CHECKED	DATE	80,000L Redstar Self Bunded Tank DRAWING NO HT80PB-48-GA-A01
			APPROVED	DATE	
			CK	09-06-2012	
			CONFIGURED	DATE	SCALE APPR MASS SHEET 1 OF REV-0
					A3